



Declaration of conformity
Déclaration de conformité
Konformitätserklärung

**Landis
+Gyr⁺**

D000062761

We
Nous
Wir

Landis+Gyr Oy
Salvesenintie 6
FI-40420 Jyskä
Finland
Business ID: 1547630-0
www.landisgyr.com/europe

declare under our sole responsibility that the products
déclarons sous notre seule responsabilité que les produits
erklären in alleiniger Verantwortung, dass die Produkte

- | | | |
|--|---------------------|---|
| <ul style="list-style-type: none">• Product Name: E360 SMR5
Single phase static meter
Compteur statique monophasé
Statischer Einphasenzähler | E360-CD2D... | Class index B
<i>Genauigkeitsklasse B</i> |
| | | Class index A
<i>Genauigkeitsklasse A</i> |

to which this declaration relates is in conformity with the requirements of the following directives
auxquels se réfèrent cette déclaration, sont conformes aux prescriptions des directives
auf die sich diese Erklärung bezieht, konform sind mit den Anforderungen der Richtlinien

- | | |
|---|--|
| <ul style="list-style-type: none">• 2014/32/EU• 2014/53/EU• 2014/30/EU• 2011/65/EU | Measuring Instruments Directive (MID)
Radio Equipment Directive (RED)
Electromagnetic Compatibility Directive (EMCD)
Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS) |
|---|--|

The conformity was assessed in accordance with the following harmonised EN-standards
La conformité fut contrôlé selon les normes EN-harmonisées
Die Konformität wurde überprüft anhand der harmonisierten EN-Normen

- | | |
|------------------------|---|
| EN 50470-1:2006 | Electricity metering equipment (a.c.) -- Part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C) |
| EN 50470-3:2006 | Electricity metering equipment (a.c.) -- Part 3: Particular requirements - Static meters for active energy (class indexes A, B and C) |

Continued on page 2



Declaration of conformity

Déclaration de conformité

Konformitätserklärung

D000062761

Landis |Gyr⁺

The conformity was assessed in accordance with the following harmonised EN-standards

La conformité fut contrôlé selon les normes EN-harmonisées

Die Konformität wurde überprüft anhand der harmonisierten EN-Normen

Safety	• EN 62052-31:2016	Electricity metering equipment (AC). General requirements, tests and test conditions. Product safety requirements and tests.
	• EN 62311:2008	Assessment of electronic and electrical equipment related to human exposure restrictions for electromagnetic fields (0 Hz - 300 GHz)
EMC	• EN 301 489-1 V2.1.1	ElectroMagnetic Compatibility (EMC) standard for radio equipment and services; Part 1: Common technical requirements; Harmonised Standard covering the essential requirements of article 3.1(b) of Directive 2014/53/EU and the essential requirements of article 6 of Directive 2014/30/EU
	• EN 301 489-3 V2.1.1	ElectroMagnetic Compatibility (EMC) standard for radio equipment and services; Part 3: Specific conditions for Short-Range Devices (SRD) operating on frequencies between 9 kHz and 246 GHz; Harmonised Standard covering the essential requirements of article 3.1(b) of Directive 2014/53/EU
Spectrum	• EN 300 220-2 v3.1.1	Short Range Devices (SRD) operating in the frequency range 25 MHz to 1 000 MHz; Part 2: Harmonised Standard covering the essential requirements of article 3.2 of Directive 014/53/EU for non-specific radio equipment

Continued on page 3



Declaration of conformity
Déclaration de conformité
Konformitätserklärung
D000062761

Landis
|Gyr⁺

Number of EC-type examination certificate. Notified Body
Numéro du certificate de lexamination type EC. Organisme notifié
Nummer der EG-Baumusterprüfbescheinigung. Benannte Stelle

- **T11033** **NMi Certin B.V., (NB number 0122)**
Hugo de Grootplein 1
3314 EG DORDRECHT
The Netherlands

Number of quality system approval certificate. Notified Body
Numéro du certificat d'approbation du system de Qualite. Organisme notifié
Nummer des Zertifikates über die Anerkennung des Qualitätsmanagementssystems. Benannte Stelle

- **6030-00143** **METAS (NB1259)**
Lindenweg 50, 3003 Bern-Wabern, Switzerland

Jan Korhonen

Matteo Biorlini

Northfieds, UK
2.10.2017

Head of IEC metering, EMEA

Vice President Quality EMEA